

ORIGINAL
File with DWR


STATE OF CALIFORNIA
THE RESOURCES AGENCY
DEPARTMENT OF WATER RESOURCES
WATER WELL DRILLERS REPORT

Do not fill in
No. 215202

Not a Permit Intent No. _____
Local Permit No. or Date _____

State Well No. _____
Other Well No. _____

(1) **OWNER:** Name Paul Soncrant
Address 19020 Hwy 36W
City Red Bluff, Ca. Zip 96080
(2) **LOCATION OF WELL** (See instructions):
County Tehama Owner's Well Number _____
Well address if different from above _____
Township 27 N Range 4 W Section 5
Distance from cities, roads, railroads, fences, etc. _____



WELL LOCATION SKETCH

(3) **TYPE OF WORK:**
New Well ☒ Deepening ☐
Reconstruction ☐
Reconditioning ☐
Horizontal Well ☐
Destruction ☐ (Describe destruction materials and procedures in Item 12)
(4) **PROPOSED USE:**
Domestic ☒
Irrigation ☐
Industrial ☐
Test Well ☐
Stock ☐
Municipal ☐
Other ☐
(5) **EQUIPMENT:**
Rotary ☒ Reverse ☐
Cable ☐ Air ☒
Other ☐ Bucket ☐
(6) **GRAVEL PACK:**
Yes ☐ No ☒ Size _____
Diameter of bore _____
Packed from _____ to _____ ft.
(7) **CASING INSTALLED:**
Steel ☒ Plastic ☐ Concrete ☐
(8) **PERFORATIONS:**
Type of perforation or size of screen _____
From ft. To ft. Dia. in. Casing or Wall Slot size
0 177 658 12
(9) **WELL SEAL:**
Was surface sanitary seal provided? Yes ☒ No ☐ If yes, to depth _____ ft.
Were strata sealed against pollution? Yes ☒ No ☐ Interval _____ ft.
Method of sealing bentonite

(10) **WATER LEVELS:**
Depth of first water, if known 37 ft.
Standing level after well completion 48 ft.
(11) **WELL TESTS:**
Was well test made? Yes ☒ No ☐ If yes, by whom? driller
Type of test Pump ☐ Bailer ☐ Air lift ☒
Depth to water at start of test _____ ft. At end of test _____ ft.
Discharge 50 gal/min after _____ hours Water temperature _____
Chemical analysis made? Yes ☐ No ☒ If yes, by whom? _____
Was electric log made? Yes ☐ No ☒ If yes, attach copy to this report

(12) **WELL LOG:** Total depth 188 ft. Depth of completed well 188 ft.
from ft. to ft. Formation (Describe by color, character, size or material)
0 - 2 Top soil
2 - 10 Fine gravel & clay
10 - 12 Gravel
12 - 14 Rock & clay
14 - 23 Clay
23 - 27 Sand & rock
27 - 32 Gravel & sand
32 - 37 Gravel & clay
37 - 40 Gravel
40 - 52 Clay
52 - 87 Hard clay & rock
87 - 94 Sandstone
94 - 100 Hard clay
100 - 125 Clay
125 - 138 Silt
138 - 142 Clay
142 - 146 Sand & gravel & clay
146 - 177 Clay
177 - 188 Sandstone

DEC 3 1985

Work started 9/7 19 85 Completed 9/7 19 85

WELL DRILLER'S STATEMENT: 00936
This well was drilled under my jurisdiction and this report is true, to the best of my knowledge and belief.
SIGNED W. S. Heitman / H.K. (Well Driller)
NAME W. S. Heitman (Person, firm, or corporation) (Typed or printed)
Address 623 Buckingham Place
City Chico, Ca. Zip 95926
License No. 324874 Date of this report 9/9/85

JOB BOOK COPY

INVOICE
NUMBER

IRRIGATION PUMP & ELECTRIC COMPANY

A BERKELEY PUMP FOR EVERY PURPOSE—A SPRINKLER SYSTEM FOR EVERY FIELD
ALL MAKES OF PUMPS OVERHAULED — FREE ENGINEERING SERVICE

Phone Flreside 2-5624 or Flreside 2-5345

19th & Park Ave.

Chico, California

CONTRACT
NO.

SOLD
BY

DATE
FINISHED

CODE

PUR. ORD.
NUMBER

CREDIT
O.K. BY

DATE

CUSTOMER

PHONE

ADDRESS

CITY

INSTRUCTIONS

PUR. ORDER ORDERED DELIVERED RETURNED USED

DESCRIPTION

AMOUNT

Draw Down in Feet Gallons Per Minute

| | |
|-----|------|
| 73' | 395 |
| 78' | 460 |
| 82 | 527 |
| 86 | 580 |
| 92 | 660 |
| 98 | 750 |
| 103 | 774 |
| 108 | 906 |
| 117 | 1050 |
| 120 | 1200 |

Setting on the Test pump was 130 Feet.

CONFIDENTIAL LOG
Water Code Sec. 13752

NET CASH. INTEREST CHARGED AFTER 30 DAYS.

MATERIAL

LABOR

TAX

TOTAL

STONER'S
NATURE